

Classification Report

Number	19-002338-PR01 (NW-A01-02-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	Three sash suspended folding & sliding door
Designation	System: SF85 Shipping name: SF85 Bifolding Thermally insulated system
Details	Manufacturer CFT-CARBON FIBER TECHNOLOGIES, PRIVATE COMPANY - Kilkis; Material Aluminium system with thermal break; Type of opening Turn / centre fold; Opening direction Active leaf right side; Overall dimensions (W x H) 3000 mm x 2600 mm
Special features	Test sequence. Position of locking. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C3/B3

Watertightness according to EN 12208:1999-11



Class: 9A

ift Rosenheim
01.07.2019



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 19-002338-PR01 PB-
A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: CDE-BC1FA