

Classification Report

Number	18-003465-PR03 (NW-B01-05-en-01)
Owner	CFT-CARBON FIBER TECHNOLOGIES PRIVATE COMPANY Industrial Area O.T.21 61100 Kilkis Greece
Product	burglar resistant facade
Designation	System: M7 Shipping name: M7
Details	Material Aluminium; Overall dimensions (W x H) 2580 x 2380; Axial dimension (W x H) 1265 x 1165; Attack side Outside of building structure; Type of opening Non opening; Screw retention agent one way screws, security plugs; LSG: Note Class: P6B according to EN 356

Special features

Result

Burglary resistance according to EN 1627:2011-05



Class: RC 4

Basis *)

EN 1627:2011-05

*) and corresponding national versions
e.g. DIN EN)

Test report: 18-003465-PR03 PB-
B01-05-en-01

Representation



Instructions for use

The results obtained apply to the field of extended application as set out in EN 1627, Annex D.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

31.01.2019



Konrad Querengässer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing



Fabian Kutscher, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 290-8548D